

TEST REPORT

REPORT DETAILS:-

Accreditation No:	90958	Client Details:	
Report/Job No:	23/06/4697(01)	Attention:	Mr.Madhu G Kaimal/ Facility Coordinator
Report Dated:	14/06/2023	Company:	Aspire Indian International School
Sample Collected by:	Libin T.Paily	Address:	Jleeb Al Shuwaikh, Kuwait.
Sample Procedure:	APHA 9060: 2017, 23 rd Ed.	Contact No:	965-55509831
Sample Appearance:	Sample collected in sterile glass bottle.	Email Address:	facilitycoordinator@daskuwait.com

Sampling Details

Sample Name:	Drinking Water	Physical Appearance:	No odor and no impurities were detected.
Sample Category:	Water	Sample Conditions:	Ambient
Sample Date & Time:	12/06/2023 & 3.20pm	Sample Received Date /Time:	12/06/2023 & 3.40pm
Sample Batch No:	-	Analysis Start Date:	12/06/2023
Sample Production Date:	-	Results Reported Date:	14/06/2023
Sample Expiry Date:	-	Sample Pick up Temperature:	26.1°C
Sample Location:	Aspire Indian International School, Jleeb Al Shuwaikh	Routine/Adhoc/Retested:	-

1.Chemical Test


Sr. No.	Testing Parameters	Results	Unit	STD Limit	Uncertainty	Remarks	Method used
1.	pH	6.9	-	6.5-8.5	-	Acceptable	APHA 4500 H B:2017, 23 rd edition
2.	TDS	16.2	mg/L	500	-	Acceptable	APHA 2540B:2017, 23 rd edition

2.Microbiological Test

Sr. No	Testing Parameters	Results	Unit	STD Limits	Uncertainty	Remarks	Method used
1.	Total plate count	<1	cfu/ml	500	-	Acceptable	APHA 9215B:2017,23 rd edition
2.	Total coliforms	<1	cfu/100ml	Zero (0) Tolerance	-	Acceptable	APHA 9222B:2017,23 rd edition

Remarks:

- All the chemical and microbiological parameters are within the acceptable limits as per USEPA Standard.
- <1 indicates that the parameters were not detected in the test conducted on the sample provided, the value indicate is notional as per the regulation related to the reporting of test value, prescribed in the applicable test methods.
- This test report relates only to the samples tested in the Laboratory.
- QLL shall not accept any liability for any decision that may be made based on this test results.

Analyzed By: Lab Technician	Indira Gandhi	
Reviewed By: Lab In-charge	Jenita A. Ponselkar	
Approved By: Lab Manager	Sudhakar Karuppiyah	

.....End of Report.....

QLL-LQS-F47 ISSUE DATE: 01/10/22 ISSUE NO: 03 Rev: 02 Page 1 of 2

صندوق بريد : ٧٦٦ السرة - ٤٥٧-٨ الكويت - الفروانية - الضجيج - قسيمة ٦٧ - الواحة مول - مكتب ٢٥

P.O.Box : 766 Al Sura, 45708 kuwait - Al Farwaniya, Al Dajeej, P lot 67, Al Waha Mall, Office 25

+965 24348731 +965 22281523 lab@qualitylifelab.com

www.qualitylifelab.com



مدرسة أسباير الهندية الدولية

ASPIRE INDIAN INTERNATIONAL SCHOOL

(DELHI WORLD PUBLIC SCHOOL)

CBSE Affiliation No. 6630261

18.11.2023

UNDERTAKING

This is to state that in Kuwait, **Water Sample Test Report** is issued by Government approved consultant and the report above states that the pH and TDS level is acceptable.

Ms. Geetika Ahuja

Principal

